




Pilot plant in Slagelse - Experiences with GAC and UV

09.03.2021

Ulf Nielsen, Ultraaqua

uni@ultraaqua.com

Where are we?



Municipality of Slagelse

- 79,000 inhabitants
- 570 km²
- 32,000 in Slagelse City

Slagelse Utility

- Multi-utility company
- Operating three large scale and 24 smaller WWTP's

Water area

- Tude Stream
- Great Belt

Focus of the project: Slagelse WWTP


- Capacity 125.000 PE
- Daily load app. 60.000 PE
- Flow: 10,000 m³/d
- Effectiveness of treatment
 - Organic matter 99%
 - Nitrogen 91%
 - Phosphorus 98%




- DOC in effluent: 7-9 mg/l

Sewer catchment:

- Slagelse Hospital (372 beds)
- Slagelse Psychiatric hospital (194 beds)





Fourth treatment step - Pilot plant setup



Key figures

- Test period from January 2019 to August 2020
 - Design flow rate: 30 m³/h
 - Disc filter: 10 µm filtration
 - GAC: 17 m³
 - UV design dose: > 40 mJ/cm², 4 lamps
-
- Total flow amount treated (august 2020): 255,000 m³ or **14,900 BV**
 - Average electricity use: **0.24 kWh/m³** (Microfiltration, pumps, GAC filtration, UV and online measurement)



GAC filter with reactivated carbon

Reactivated carbon (Organosorb 20) was used

- Virgin fossil carbon: 11-18 tons CO₂-equivalents per tons produced
 - Reactivated carbon: 2-3 tons of CO₂-equivalents per tons produced
- = Carbon footprint: **6 times lower than virgin fossil carbon**

Carbon particle size: 1.7 mm (0.42-2.8)

Filter: 17 m³

EBCT was between 34 to 43 minutes

Carbon usage after 14,900 BV: 30 mg GAC/l

Backwashed six times:

Backwash	BV	Comments
03-06-2019	2,323	Treated wastewater. Sampling of backwash water after 15 minutes
31-07-2019	3,769	Treated wastewater.
11-11-2019	5,987	Treated wastewater. Sampling of backwash water after 5 and 10 min.
04-03-2020	10,482	Treated wastewater
17-03-2020	11,044	Treated wastewater
07-07-2020	14,066	Treated wastewater and air




Micropollutants and microbiology measured

Micropollutants

- Laboratories: Kristianstad Uni. (S) and IUTA (G)
- 44 micropollutants (pharmaceuticals, industrial chemicals, pesticides and contrast media)


	Number
Total number of analyses	2,296
Total number of analyzed parameters	44
Kristianstad parameters	37
IUTA parameters	7



Microbiology


- Laboratories: Slagelse Utility and DHI (antibiotic resistance)
- Culturable bacteria 22 °C and 37°C, Escherichia coli and Enterococci
- Vancomycin resistant enterococci (VRE), Carbapenem resistant Enterobacteria (CPE) and Cephalosporin Resistant E. coli (CEF)

Removal in the conventional WWTP




Conventional WWTP effluent

14 critical micropollutants measured $>PNEC_{\text{Freshwater}}$



Average concentrations of pollutants measured above $PNEC_{\text{Freshwater}}$.




Ratio between measured concentrations (MEC) and predicted no-effect concentrations ($PNEC_{\text{Freshwater}}$)

Pilot plant effluent


6 micropollutants measured $>PNEC_{\text{Freshwater}}$ after 14,900 BV

Measured effluent concentration (MEC)



Effluent concentration from pilot plant.


Effluent risk ratio (MEC/PNEC)



Ratio between measured concentrations (MEC) and predicted no-effect concentrations ($PNEC_{\text{Freshwater}}$)

Removal efficiency from WWTP influent to pilot plant effluent

All 34 micropollutants




* Reduction of total concentration relative to WWTP inf.


** Reduction relative to WWTP eff.

Removal efficiency from WWTP influent to pilot plant effluent

14 critical micropollutants



11 Swiss substances




* Reduction of total concentration relative to WWTP inf.

** Reduction relative to WWTP eff.


Removal efficiency from WWTP influent to pilot plant effluent

14 critical micropollutants

	Conventional WWTP plus pilot plant removal percentage							
BV	969	2442	4541	6026	8986	10322	12665	14.882
Diclofenac	100	98	92	92	80	79	50	63
PFOS	99	97	75	73	92	90	16	63
Oxazepam	100	100	98	96	85	79	72	76
Venlafaxine	100	100	99	94	72	73	59	81
Carbamazepine	100	100	98	98	87	81	73	83
Tramadol	100	100	99	98	85	86	78	88
Azithromycin	100	91	88	70	68	88	70	89
Clarithromycin	98	95	89	90	86	82	87	91
Metoprolol	100	100	99	100	91	86	86	93
Bisphenol A	99	97	96	91	96	89	94	95
Citalopram	100	100	100	100	96	92	92	97
Methylbenzotriazol	98	98	99					97
Benzotriazole	100	100	100	100	99	98	98	98
Ciprofloxacin	100	100	100	99	100	98	97	99
Sertraline	100	100	100	100	100	100	100	99
Propranolol	100	100	100	100	99	95	98	99
Estrone	100	100	100	100	100	97	100	99
Total removal 14 substances	100	98	95	92	89	89	78	88



GAC breakthrough of the 6 critical pollutants and DOCEq




Probably biofilm
formation in GAC

Change of
adsorption and
degradation
properties

Reduction of critical pollutants plus DOCEq in the pilot plant. The dotted line indicates the trend for the development of the DOCEq


Overview of GAC breakthrough of 14 critical substances and 11 Swiss substances



Disinfection by UV in pilot plant

Results from WWTP effluent, after GAC and after pilot plant (PP)

- Efficient removal of *E. coli* and resistant bacteria
- PP effluent complies with Danish Drinking Water Act and EU regulation on reclaimed water for agricultural irrigation



Antibiotic resistant bacteria

Unit	Enterococci		Coliform			<i>E. coli</i>		
	Total MPN/100 ml	VRE CFU/100 ml	Total MPNCFU/100 ml	CPE CFU/100 ml	CEF CFU/100 ml	Total MPNCFU/100 ml	CPE CFU/100 ml	CEF CFU/100 ml
Influent WWTP	950,000	13,000	42,500,000	455	369,500	1,690,000	182	92,350
Effluent WWTP	10,750	424	292,500	<20	12,500	17,950	<20	1,325
After GAC	1,520	49	17,500	<20	673	2,185	<20	237
Effluent PP	<1	<1	<50	<20	<20	<50	<20	<20

VRE: Vancomycin resistant enterococci
 CPE: carbapenem resistant Enterobacteria
 CEF: Cephalosporin resistant *E. coli*

Sampled 27.02.2020.

Investment and operational costs

- Total pilot plant investment: 210,000 EUR
- Original budget was: 104,000 EUR. The expansion covered mainly new pumps and backwash system with air
- Man-hours for operation: 3 hours / week

Estimate of future cost for full scale implementation


- Estimate based on a linear write-off over 15 years and assuming a GAC-filter loading of 46,000 BV (five filter shifts) which corresponds to a **carbon usage of 10 mg/l**
- Drum filter, building, pumps & pipes, GAC filter unit and UV: 120,000 EUR, and each GAC filter filling (including GAC transport costs) is estimated to 16,200 EUR.
- Including electricity consumption (0.013 EUR/m³) and manpower for maintenance (0.019 EUR/m³) the total estimate amounts to:

0.088 EUR/m³ (0.66 DKK/m³)

Next steps in Slagelse

- A new project (OxyTreat) with expansion of the pilot plant with oxidation processes
- Funded by Danish EPA, Time schedule: 2021-2022
- Planning is started – new technologies will be in place after summer holiday
- Full-scale solution are to be implemented before 2025

New pilot plant setup



Most important takeaways

- Overall GAC was effective ($\geq 80\%$) for removal of critical micropollutants
- 6 pollutants were breaking through after 15,000 BV
- Effluent complies with criteria from DK drinking water and EU regulation on water reclamation
- Total cost for full scale implementation is estimated to 0.088 EUR/m³
- A new follow-up project (Oxytreat) are to reduce breakthroughs and increase GAC durability

THANK YOU FOR YOUR ATTENTION!

Ulf Nielsen, Ultraaqua A/S
uni@ultraaqua.com

